

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210556  
Address: 326 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Eric Sharp	Failed	Friday, November 19, 2021

Informational:  
1 Misc Driveway is framed up with aggregate in and compacted. Framing meets LS and ADA spec. 11/12 ES

Corrective Action Required:  
2 Misc Driveway meets LS and ADA spec. However, curb line needs patched in multiple locations. 11/19 ES

**Comments:**