

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20214591  
Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Commercial</b>	Michael Harkins	Partial	Friday, November 19, 2021

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	STUB OUTS FOR ROOF DRAINS EXITING BLDG PROVIDE BOCA PLATES AT THESE LOCATIONS
---	--	--

**Comments:**