

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210623
Address: 2118 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Friday, November 19, 2021

Corrective Action Required:

1	Miscellaneous Correction	11/19/21 THIS HOUSE IS NOT READY COMPLETE BELOW ITEMS BEFORE RESCHEDULING THIS LIST IS INCOMPLETE SUBJECT TO CHANGE AS TRADES COMPLETE WORK East wall needs to be rated as per section R302 2018 IRC Fire caulk soffit blocking west wall garage Seal all upward & exterior penetrations Fire blocking fireplace Secure fireplace
---	--------------------------	--

Comments: