

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20214591  
Address: 1103 SW OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Roof Drain</b>	Ronald Paynter	Passed	Friday, November 19, 2021

Informational:  
1 Misc

Roof drains were attached to 4 inch SCH 40 pipe. Ask Gary from Harmon to add a 45 degree bend near the end section to get clearance from a buried water valve. Also informed Water about the buried water valve. RP 11-19-21

**Comments:**