

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210263

Address: 1801 NW OBRIEN RD, LEES SUMMIT, MO 64081 520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	Ronald Paynter	Partial	Monday, November 22, 2021

Informational:

1	Misc	Dechlorinated the water line. Letting it set over the weekend. Planning on pulling 1st Bac T samples on Monday. RP 11-19-21
---	------	---

Informational:

2	Misc	Dechlorinated the water line. Letting it set over the weekend. Planning on pulling 1st Bac T samples on Monday. RP 11-19-21
---	------	---

Informational:

3	Misc	
---	------	--

Comments: