

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213082
Address: 4729 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Suspended Slab Inspection	Khanh Nguyen	Failed	Monday, November 22, 2021

Corrective Action Required:

1	Misc	-Install corner rebars per plan -Fasten decking to steel beam per plan **Have Apex engineeer address the 36"x36" I beam support pad and I beam not present at NW side of garage
---	------	---

Comments: