

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213070
Address: 4817 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|--------------|----------|---------------------------|
| Suspended Slab Inspection | Khanh Nguyen | Failed | Monday, November 22, 2021 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -Fasten the deck to the I beam per plan. 2 fastener every 12" oc -Install 2 rebars at each corner per plan -The 10 ft rebar along the length of the I beam must be 1"-1.5" below the surface of the slab. Install chairs to raise these 10 ft rebars to proper height |
|---|------|---|

Comments: