

*David P. Ainsworth, P.E.*  
*1200 NW Hearn Ave, Blue Springs, MO 64015*  
*Cell Phone: 816-682-2093*  
*Email: dainsworth@chelepis.com*

November 22, 2021

Mr. Mark Yancik  
508 NW Manor Drive  
Blue Springs, MO 64014

Re: Property @  
540 SE Carter Rd  
Lee's Summit, MO.  
Lot 30 Colby Creek  
Inspection Issues

Dear Mr. Yancik:

On November 22, 2021, I inspected the above referenced property to address framing issues raised by the Building Inspector.

1. Have engineer clarify size and number of studs required at all beams as not noted on plans.

There should be 3 @ 2x4 Studs to support ends of all beams.

Cordially,



David P. Ainsworth, P.E.



*David P. Ainsworth*  
11-22-21