

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212324
Address: 2934 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, November 23, 2021

Informational:

1 Misc

-GARAGE PORTAL EXTERIOR ONLY OK TO COVER

Corrective Action Required:

2 Misc

-dbl top plate requires 24" offset between plate breaks - see garage west wall
-unable to inspect covered deck trusses due to cover
-Install basement egress window

Comments: