

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212468
Address: 4729 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------|--------------|----------|----------------------------|
| Water Service Inspection - R | Khanh Nguyen | Failed | Tuesday, November 23, 2021 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | MIN 3/4" GRAVEL IS NOT PROVIDED AT DRIVEWAY. SPREAD OUT THE GRAVEL TO THE STREET CURB. |
|---|------|--|

Comments: