

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215902  
Address: 2245 SW WALDEN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Residential</b>	Shawn Hoffman	Failed	Tuesday, November 23, 2021

Corrective Action Required:

1	Miscellaneous Correction	<ul style="list-style-type: none"><li>- install afci protection</li><li>- electrical panel not allowed in bathroom</li><li>- need 36" access to panel</li><li>- smoke detectors not interconnected</li><li>- not enough combustion air , make opening larger</li></ul>
---	--------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**