CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213762

Address: 2924 NW THOREAU DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underground Plumbing Michael Harkins Failed Tuesday, November

Inspection - Residential 23, 2021

Corrective Action Required:

1 Miscellaneous PROVIDE MINIMUM 10 PSI FOR 15 MIN GAS LINE PRESSURE TEST FOR POOL

Correction HEATER & GENERATOR

Comments: