

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210467
Address: 2049 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, November 23, 2021

Corrective Action Required:

2	Misc	-complete final grade and sod -check water meter at time of final grade and sod -splash blocks and sump pump discharge 36" from foundation -no set screw Anti-siphon device--sheer off set screw
---	------	---

Comments: