

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215295
Address: 2110 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Mark Harding	Failed	Wednesday, November 24, 2021

Corrective Action Required:

1	Misc	interior drain tile needs to be installed where it will drain not 3' low areas. - support all DWV with gravel - Support or strap DWV in over dig areas to basement floor.
---	------	---

Comments: