

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212324  
Address: 2934 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:   | Outcome: | Date:                        |
|-------------------------------------------|--------------|----------|------------------------------|
| <b>All Rough Inspection - Residential</b> | Mark Harding | Failed   | Wednesday, November 24, 2021 |

Corrective Action Required:

2 Misc

-unable to inspect covered deck trusses due to cover \*\* south truss over sliding door missing H2.5.  
-Install basement egress window\*\* south window not in.  
Remove Jonny from the street. clean gravel out of the street and repair silt fence at front of lot.

**Comments:**