

**1 ROOF - PIPING/ELECTRICAL**  
1/4" = 1'-0"

**SHEET NOTES:**  
1. REFER TO GENERAL NOTES ON SHEET M000.1 AND E000.1.


**KEYNOTES:** **B**  
1. COORDINATE EXACT LOCATION OF NEW CONDENSING UNIT WITH STRUCTURAL ENGINEER. MAINTAIN 3' OF SPACE AROUND OF SPACE AROUND UNIT FOR SERVICE AND INSTALL NOT LESS THAN 10' FROM EDGE OF ROOF.

**IMEG** 1600 BALTIMORE SUITE 300  
KANSAS CITY, MO 64108  
816.842.8437  
www.imegcorp.com  
PROJECT # 21003531.00

Missouri State Certificate of Authority E-201700830

IMEG CORP. RESERVES PROPRIETARY RIGHTS, INCLUDING COPYRIGHTS, TO THIS DRAWING AND THE DATA SHOWN THEREON. SAID DRAWING AND/OR DATA ARE THE EXCLUSIVE PROPERTY OF IMEG CORP. AND SHALL NOT BE USED OR REPRODUCED FOR ANY OTHER PROJECT WITHOUT THE EXPRESS WRITTEN APPROVAL AND PARTICIPATION OF IMEG CORP. © 2021 IMEG CORP.

REFERENCE SCALE IN INCHES  
0 1 2 3



Bruce E. Hart  
Missouri #E-22817

**ACI BOLAND ARCHITECTS**  
1710 Wyandotte  
Kansas City, MO 64108  
T: 816.763.9600

ACI/Boland, Inc.  
Kansas City | St. Louis  
Licensee's Certificate of Authority Number:

**MEP CONSULTANT**  
**IMEG**  
1600 Baltimore, Suite 300  
Kansas City, MO 64108  
Phone Number: 816-842-8437

**Saint Luke's ED Finish Upgrades**  
**80 NE Saint Luke's Blvd**  
**Lee's Summit, MO 64086**

Date 11/12/21  
Job Number 3-21024  
Drawn By MJL/PLR  
Checked By BEH

Revision		
Number	Date	Description
5	11-29-21	City Comments

**ME202.1**  
© 2021 ACI/BOLAND, Inc.  
ROOF - PIPING/ELECTRICAL