

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20204934  
Address: 1440 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                            | Inspector:      | Outcome:  | Date:                           |
|--|-----------------|-----------|---------------------------------|
| <b>Footing Inspection - Commercial</b> | Michael Harkins | Not Ready | Wednesday,<br>November 24, 2021 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | -Provide city approved, stamped plans<br>-Provide 3" clearance around rebar<br>-Northeast corner of footing not 3' below grade |
|---|------|--|

**Comments:**