

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212324
Address: 2934 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Monday, November 29, 2021

Corrective Action Required:

1	Misc	-unable to inspect covered deck trusses due to cover ** sotuh truss over sliding door missing H2.5. -Install basement egress window** south window not in. Remove Jonny from the street. clean gravel out of the street and repair silt fence at front of lot.
---	------	--

Comments: