

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210387
Address: 3208 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Monday, November 29, 2021

Corrective Action Required:

- | | | |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none">- obtain irrigation permit and submit a back flow certification- Final grading and sod- Place splash blocks- seal top of meter can- Sump discharge 36" away from foundation
- Secondary lock on sliding door- In garage, non-GFCI outlet & GFCI outlet are reversed |
|---|--------------------------|---|

Comments: