CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20210263Address:1801 NW OBRIEN RD, LEES SUMMIT, MO 64081520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspectio	on:	Inspector:	Outcome:	Date:
Water Lii	ne - Coliform Test 2	Ronald Paynter	Failed	Monday, November 29, 2021
Informational:				
1	Misc	Pulled 3 more samples for Bac T testing. Delivered samples to Keystone Laboratories for testing. Still waiting to hear back on the first test. RP 11-23-21		
Corrective Action Required:				
2	Misc	First and second Bac T samples failed testing. They are re-chlorinating the water line. RP 11-29-21		
Corrective Action Required:				
3	Misc	First and second Bac T san water line. RP 11-29-21	nples failed testing. They a	re re-chlorinating the

Comments: