

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202689
Address: 2345 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Passed	Tuesday, November 30, 2021

Corrective Action Required:

1	Miscellaneous Correction	OK to rock -Provide ledger to house connections and (2) 1/2" through bolts at post to beam connection at deck
---	--------------------------	--

Comments: