

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20204989  
Address: 3026 NW THOREAU PL, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Not Ready	Tuesday, November 30, 2021

Corrective Action Required:

- |   |                          |   |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none"><li>- final grading and sod</li><li>- Lock and secondary lock for sliding door</li><li>- Outlet dead east island</li><li>- Missing outlet/open box in cabinet near refrigerator</li><li>- Missing fixtures over stairs open box</li><li>- Open box stairs to basement</li><li>- Non GFCI in basement needs labeled</li><li>- Provide security screws in basement door</li><li>- Missing floor registers first floor</li></ul> |
|---|--------------------------|---|

Comments: