

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20204934
Address: 1440 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|-----------------|----------|----------------------------|
| Footing Inspection - Commercial | Michael Harkins | Partial | Tuesday, November 30, 2021 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Northeast corner of footing not 3' below grade - UPLOAD SPECIAL INSPECTION REPORTS TO PERMIT: PLACEMENT OF STEEL, PLACEMENT OF CONCRETE, TESTING OF CONCRETE - - UFER LOCATED NW CORNER OF BUILDING - OK TO POUR |
|---|------|--|

Comments: