

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210580
Address: 711 SE M 291 HWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|------------|----------|----------------------------|
| Above Ceiling Inspection | Robb Popp | Failed | Tuesday, November 30, 2021 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Provide fire proof shield or proper 3' clearance to ceiling at MDP per manufacturer -Install (2) tie wires at opposite corners on all light fixtures-south row and bathroom -Sheet rock and seal gaps between HVAC in mechanical room -Perform gas pressure test |
|---|------|--|

Comments: