

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210281
Address: 1509 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, November 30, 2021

Corrective Action Required:

1	Misc	-seal along top of meter can -master bath jacuzzi tub motor needs GFCI protection -all smokes to be operational and interconnected -flashing at rear great room window exterior trim
---	------	---

Corrective Action Required:

2	Misc	-Remove debris from water meter well- provide 12" of clearance below water meter assembly.
---	------	--

Comments: