

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20211543  
Address: 1905 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:   | Outcome: | Date:                      |
|---|--------------|----------|----------------------------|
| <b>All Rough Inspection - Residential</b> | Khanh Nguyen | Failed   | Tuesday, November 30, 2021 |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 1 | Misc | -Complete electrical to fireplace **plug connection must be accessible at final                  |
|   |      | -Install collar tie above living room  |
|   |      | -Anchor garage wall sill plate per code with max spacing no more than six ft                     |
|   |      | **Cannot reduce the shower drain to 1.5" pipe. Shower drain must be min 2". You have to fur down |

**Comments:**