

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213690
Address: 1217 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, December 01, 2021

Corrective Action Required:

1	Misc	-Have engineer address 2x4 stud walls exceeding 12 ft height at garage, foyer
		-Hangers not fully bailed. Support rafters at lvl connections in 2nd fl hallway bathroom by installing 2x2 blocking underneath rafters **blockings not doing any support purpose if there is significant gaps under the rafters

****OK TO INSULATE**

Comments: