

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214148
Address: 1736 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Michael Harkins	Failed	Wednesday, December 01, 2021

Corrective Action Required:	
1	Miscellaneous Correction
	Provide cover open J box above water heater Support NM & low voltage above walk in cooler near back door & POS counter Complete HVAC above walk in cooler

Comments: