## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20211710

Address: 2345 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Shawn Hoffman Failed Wednesday,

Residential December 01, 2021

Corrective Action Required:

1 Miscellaneous - fire block penetration return air space at basement bathroom by furnace

Correction - Nail corner bedroom 3

Add support to IvI from twisting over stairs
 Fire block penetration in return bedroom 2
 Address missing vent boot master closet

- Security block back doors 3 stud bays

- Address over bored 3 pack 2x4's master bedroom fire place IvI support

- Address missing vent boot above kitchen and throughout

- Keep outlet accessible for master tub

- Nail outside sheeting sill plate

## Comments: