

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212070
Address: 209 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Not Ready	Thursday, December 02, 2021

Corrective Action Required:

1	Miscellaneous Correction	- FRONT PORCH PROVIDE ENGINEERS LETTER ADDRESSING FIELD MODIFICATIONS TO TRUSSES E3,E4,E5, - - COVERED DECK APPROVED OK TO COVER - - PFH PORTAL FRAME GARAGE NAIL TOP PLATE TO HEADER PER PLANS (2) ROWS 16D SINKERS 3" O.C. CHECK ON ROUGH IN, OK TO COVER EXTERIOR
---	--------------------------	--

Corrective Action Required:

2	Misc	PROVIDE CITY STAMPED PLANS FOR INSPECTION.
---	------	--

Comments: