

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212664
Address: 4050 SE DOC HENRY RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Deck Final Inspection - Residential	Mitchell Schwarz	Failed	Thursday, December 02, 2021

Corrective Action Required:

1	Misc	-guard rail shall not have openings from the walking surface to the required guard height that allow passage of a sphere 4 inches in diameter(see south guard rail) -outlets in sunroom area not currently working. Mitchell Schwarz 12/02/2021 10:57 AM
---	------	---

Comments: