

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210599
Address: 2051 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Thursday, December 02, 2021

Corrective Action Required:

1	Miscellaneous Correction	OK TO STOCK & TRAIN ONLY ADDRESS BELOW CODE ITEMS & CALL FOR REINSPECT FOR TCO Mens toilet flush valve wring side ADA restroom signs wrong height Install Vertical grab bars restrooms per plan Complete drive thru window
---	--------------------------	---

Comments: