

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20210775  
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water - Material Verification</b>	Ronald Paynter	Passed	Thursday, December 02, 2021

Informational:  
1 Misc All the fittings, sleeves, gate valves and fire hydrants are epoxy coated. Gate valves and fire hydrants were manufactured by Mueller and meet our approved products list. RP 12-2-21

**Comments:**