

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20211138
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water - Material Verification	Ronald Paynter	Passed	Thursday, December 02, 2021

Informational:
1 Misc All the fittings, sleeves, gate valves and fire hydrants are epoxy coated. Gate valves and fire hydrants were manufactured by Mueller and meet our approved products list. RP 12-2-21

Comments: