CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210263

Address: 1801 NW OBRIEN RD, LEES SUMMIT, MO 64081520 NW HOPE LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Water Line - Coliform Test 1 Ronald Paynter Passed Friday, December 03,

2021

Corrective Action Required:

1 Misc Water samples from Moore and Hope passed first Bac T testing, but the

sample taken from Peace failed. Notified Mark from Rodriguez Mechanical

about the results. RP 11-24-21

Informational:

2 Misc Chlorinated the water line again due to 2 failed Bac T test. RP 11-29-21

Informational:

3 Misc Dechlorinated the water line. Ready to pull Bac T samples tomorrow

morning. RP 11-29-21

Informational:

4 Misc Pulled first samples and delivered them to Keystone Laboratories for testing.

RP 12-1-21

Informational:

5 Misc The first samples pulled on 12/1 passed testing from Keystone Laboratories.

RP 12-3-21

Comments: