

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210880
Address: 2118 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Monday, November 22, 2021

Corrective Action Required:

1	Miscellaneous Correction	Address bores in LVL above refrigerator (DON'T SEE ENGINEER'S LETTER UPLOADED) LETTER DID NOT ADDRESS HVAC BORED THROUGH LVL ABOVE PANTRY DOOR - 11/22/21 PROVIDE DOUBLE LVL PER ENGINEERS LETTER/DRAWING SOUTH OF FURNACE IN BASEMENT -
---	--------------------------	--

Comments: