

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211430
Address: 134 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Failed	Friday, December 03, 2021

Informational:

1	Misc	Driveway was framed up with aggregate in and compacted. Needs a section of curbing replaced at driveway. 11/23 ES
---	------	---

Corrective Action Required:

2	Misc	Driveway meets LS and ADA specs. Still needs to replace busted curb. RP 12-3-21
---	------	---

Comments: