CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20212196

Address: 1630 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Sanitary Sewer Construction Adam Nacke Passed Friday, December 03,

Inspection 2021

Informational:

1 Misc 7/19/21 Monday

Contractor began installation of sanitary Line E of the 8th Plat. Approximately

225' of Line E was installed.

Partial Correction:

2 Misc 11-3-21 AN Holthouse is digging up all the damaged MHs form the failed

camera test for repair. After completed water needs to come out and

reinspect.

Informational:

3 Misc 12-3-21 AN water came out and reinspected all of the failed items from the

camera test and said that all of the issues have been corrected

Comments: