

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210587
Address: 1505 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, December 03, 2021

Corrective Action Required:

1 Misc

-anti tilt device on oven
-SUMP PUMP DISCHARGE, SPLASH BLOCKS AND ALL OTHER EXTERIOR DRAINAGE TO BE 36" FROM FOUNDATION

Comments: