

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214889
Address: 1215 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Not Ready	Tuesday, November 09, 2021

Corrective Action Required:

1	Misc	**11-9-21 NOT READY FEE ACCESESSED-PAY FEE BEFORE ANY FURTHER INSPECTIONS
---	------	--

- Fire approval required
- Provide permanent accessible restroom signage on latch side of door

Comments: