

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210506  
Address: 1713 SW 26TH TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Friday, December 03, 2021

Corrective Action Required:

2 Misc

- Seal penetration under master shower
- Ridge support over back porch
- Provide 1" clearance for bvent at roof and second floor
- Get ductwork off flue in back bedroom
- Patch hole in roof front bedroom
- Nail joists hangers basement under shower
- Seal penetration basement ductwork though return vent by sub panel
- Address over bored joists in pantry
- Address plumbing above pantry 45.45.90 ?

**Comments:**