

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210427
Address: 250 NW MCNARY CT, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Monday, December 06, 2021

Corrective Action Required:

1	Miscellaneous Correction	: IN WALL NORTH END (SHELL PERMIT) PROVIDE MIDPOINT SUPPORT VERTICAL 2" & SMALLER DWV ROOM 112 NAIL BOTTOM PLATE BEHIND DOOR
---	--------------------------	--

Comments: