

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213111
Address: 1801 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, December 06, 2021

Corrective Action Required:

1 Misc

****BASEMENT FINISH ADDED****

-FIREBLOCK CHASE AT BASMENT BATH
-UFER WILL NEED TO REMAIN ACCESSIBLE AT FINISH, BASEMENT BATH
-UFER, REPLACE ACORN STYLE CLAMP WITH CLAMP LISTED FOR REBAR, SEPARATION AT UFER WITH GEC CONDUCTOR

Comments: