

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203927
Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Monday, December 06, 2021

Informational:	
1 Misc	-PHASED OCCUPANCY APPROVALS- -Restrooms -Office area -Meat & seafood -Bakery -Floral-Customer service-Clinic,Asian, hibachi, & pizza area;phyarmacy,Starbuck's, Sports Shop,
Corrective Action Required:	
2 Misc	Clinic area- -install water heater and drain , TRV to the correct location per code. install approved piping. -insulate water pipes above ceiling.

Comments: