

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20203927  
Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Michael Harkins	Partial	Monday, December 06, 2021

Informational:

1	Misc	8/12 - CEILING ABOVE STARBUCKS AND FRONT NORTH VESTIBULE OK
		9-23- Hard lid and soffit in sports shop ok
		12-6-21 AISLES ONLINE AREA REAR OF STORE OK TO DROP CEILING TILE -

Corrective Action Required:

2	Misc	8/17 - PHARMACY/HEALTH ABOVE CEILING;  TEMP LIGHTING AND EXISTING LIGHTING OK DUE TO DELAY IN SHIPMENT OF NEW LIGHTING, WILL NEED TO SEE ABOVE CEILING AT NMEW FIXTURES WHEN INSTALLED FOR FINAL ABOVE CEILING
---	------	--

Comments: