

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20202008
Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	Ronald Paynter	Partial	Tuesday, December 07, 2021

Informational:
1 Misc Chlorinated water lines for O'Brien, Patch and Killarney. Will let them set over the weekend. RP 12-3-21

Informational:
2 Misc Dechlorinated the water line. RP 12-6-21

Comments: