CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211516

Address: 2350 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Shawn Hoffman Failed Tuesday, December

Residential 07, 2021

Corrective Action Required:

1 Misc -Pay fees

-Final grading and sod

-Splash blocks

-sidewalk and inspection

-spark rings needed at kitchen counter

- install tub in master

- No smoke alarms working

- No set screw in back flow preventer at water main

- Water heater not operational

- No ladder for Egress window

- basement stairs handrail not in compliance, code R311.7.8.4 stops short of

bottom riser

- basement stairs top and bottom riser over 7 3/4"

Comments: