

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204939
Address: 2115 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Michael Harkins	Partial	Tuesday, December 07, 2021

Corrective Action Required:

1	DCM8 Water Meter Height	THE TOP OF THE WATER METER TO BE SET AT A DEPTH OF 14 TO 18 INCHES BELOW THE WATER METER LID.
---	-------------------------	---

: PARTIAL OK TO COVER HOUSE TO PIT CORRECT LID HEIGHT :

Comments: