

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215940
Address: 625 NW EDGEWOOD CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Robb Popp	Partial	Wednesday, December 08, 2021

Corrective Action Required:

1	Misc	WATER BOND REQUIRED, MIN 9 SQ IN SURFACE AREA REQUIRED, NEC 680.26 (2) (C) -VERIFY AT FINAL- LOCATED IN-LINE AT EQUIPMENT PAD- 4" SLEEVE OUTSIDE OF PAD
---	------	--

Comments: