CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20211710Address:2345 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------------|---------------|----------|---------------------------------|
| All Rough Inspection - Residential | Shawn Hoffman | Failed | Wednesday, December 08, 2021 |

Corrective Action Required:

| 1 | Miscellaneous | - fire block penetration return air space at basement bathroom by furnace (|
|---|---------------|---|
| | Correction | by pex) |
| | | Fire block penetration in return bedroom 2 |
| | | Security block back doors 3 stud bays |
| | | Address over bored 3 pack 2x4's master bedroom fire place lvl support |
| | | - Keep outlet accessible for master tub |
| | | - Nail outside sheeting sill plate |
| | | |

Comments: